


- EVERGUARD® BONDING ADHESIVE (OPTIONAL)
- EVERGUARD® WATER BLOCK OR FLEX SEAL™ CAULK GRADE
- EVERGUARD® COATED OR GALVANIZED METAL COUNTERFLASHING
- EVERGUARD® WATER BLOCK OR FLEX SEAL™ CAULK GRADE
- DRILL-TEC™ PLATES & SCREWS 12" (305 mm) O.C. (6" [152 mm] O.C. FOR BALLASTED SYSTEMS)
- THRESHOLD BY OTHERS
- HEAT-WELDED LAP
- REINFORCED EVERGUARD® MEMBRANE
- EVERGUARD® WALK PAD (REQUIRED)
- ENERGYGUARD™ ROOF INSULATION
- ROOF DECK/SUBSTRATE

NOTE:

ALTERNATE BASE
REFER TO EVERGUARD DETAIL 307



1. FOR INSULATION THICKNESS GREATER THAN 8" (203 mm), A HARD BOARD IS REQUIRED ON MECHANICALLY FASTENED SYSTEMS ONLY.
2. REFERENCE EVERGUARD® DETAIL 609.
3. WALKWAY PAD OR PAVER WITH SLIP SHEET REQUIRED AT ALL ROOF ACCESS POINTS. FOR BALLASTED ATTACHED SYSTEMS PAVER IN LIEU OF PAD AND BALLAST PER SPEC.
4. IF EVERGUARD® FREEDOM™ MEMBRANE IS USED, BONDING ADHESIVE IS NOT NEEDED AND WALL MUST BE PRIMED.
5. FOR SELF-ADHERED RAPIDSEAM™ TECHNOLOGY SYSTEMS, SEE EVERGUARD® DETAIL 330 FOR LAP APPLICATION.
6. APPLY EVERGUARD® TPO CUT EDGE SEALANT TO ALL CUT REINFORCED TPO EDGES (REFER TO EVERGUARD® DETAIL 115).

 www.gaf.com 1 Campus Drive, Parsippany, NJ 07054	 SINGLE-PLY ROOFING SYSTEMS PARAPET WALL & CURB SERIES	DRAWING #	312 THRESHOLD FLASHING DETAIL	THIS DETAIL APPLIES TO:
		SCALE		REVISION DATE
		N.T.S.		ALL SYSTEMS 6-20-16