



**NOTE:**

1. FOR INSULATION THICKNESS GREATER THAN 8" (203 mm), A HARD BOARD IS REQUIRED ON MECHANICAL SYSTEMS ONLY.
2. FIELD-FABRICATED EXPANSION JOINT SHOULD BE SMOOTH BACKED MEMBRANE ONLY
3. APPLY EVERGUARD® TPO CUT EDGE SEALANT TO ALL CUT REINFORCED TPO EDGES (REFER TO EVERGUARD® DETAIL 115).



**EverGuard**  
SINGLE-PLY ROOFING SYSTEMS  
EXPANSION JOINT  
SERIES

DRAWING #  
**404B**

**FIELD FABRICATED WALL  
EXPANSION JOINT DETAIL - CURB  
TYPE**

THIS DETAIL APPLIES TO:

**ALL SYSTEMS**

www.gaf.com  
1 Campus Drive,  
 Parsippany, NJ 07054

SCALE  
N.T.S.

REVISION DATE  
5-25-16