



NOTE:

1. BEFORE APPLICATION OF UNITED COATINGS™ PMMA FLASHING MEMBRANE, FLEXSEAL™ CAULK GRADE SEALANT SHOULD BE USED TO FILL VOIDS WHERE ROOFING MEMBRANES TERMINATE AT PENETRATIONS.
2. REFER TO GAF PREPARATION GUIDELINES FOR PROPER SURFACE TREATMENT OF ALL MATERIALS PRIOR TO APPLICATION OF UNITED COATINGS™ PMMA FLASHING SYSTEM.
3. A NAILER AND TREATED WOOD CANT MAY BE REQUIRED FOR COMPLIANCE WITH SPECIFIC BUILDING CODES OR APPROVALS.
4. UNITED COATINGS™ PMMA CANNOT BE APPLIED IN THE ABOVE CONFIGURATION OVER MEMBRANES OR OTHER MATERIALS CONTAINING UNCURED, SOLVENT-BASED MATERIALS. CONTACT GAF FOR INFORMATION.
5. REFER TO GAF FLEECE CUTTING RECOMMENDATIONS FOR CONFIGURATIONS, CUTTING, FOLDING, AND LAPPING TECHNIQUES.
6. REQUIREMENTS AND RECOMMENDATIONS DETAILED IN CURRENT GAF SPECIFICATIONS AND THE UNITED COATINGS™ PMMA FLASHING SYSTEM INSTALLER'S GUIDE SHALL APPLY IN ADDITION TO THE ABOVE DRAWING.
7. DO NOT USE OVER COLD-APPLIED SYSTEMS.



www.gaf.com
1 Campus Drive,
Parsippany, NJ 07054

BRAND SERIES
**UNITED
COATINGS**

REVISION DATE
11-21-17

SCALE
N.T.S

**EXISTING LOW WALL FLASHING W/
SELF-TERMINATING PMMA FLASHING
DETAIL**

DETAIL #

301

SYSTEM

PMMA